

(6)

OFFICE OF THE EXECUTIVE ENGINEER, CONSTRUCTION DIVISION, U.P. JAL NIGAM, HAPUR
TEST REPORT

Name of District & Block - Hapur and Garhmukteshwar

Sample received date - 17/03/2023

Name and Designation of the person responsible to collect the sample - Sh. Aanandram

Date of sample testing - 18/03/2023

| Sr No. | Location of the source. | Turbidity 1.00 to 5.00 | TDS 500 to 2000 mg./l | pH Value 6.50 to 8.50 NTU | Chloride 200 to 1000 mg./l | Flouride 1.00 to 1.50 mg./l | Iron 0.10 to 1.00 mg./l | No3 45 | Hardness 200 to 600 mg./l | Alkalinity 200 to 600 mg./l | Conductivity | Result |
|--------|--|---------------------------------|-----------------------------------|--|-------------------------------------|-----------------------------------|-------------------------------------|-----------|---------------------------------------|---|--------------|--------|
| | 2 | 3 | 4 | 5 | 6 | 7 | 9 | 10 | 11 | 12 | 13 | 14 |
| 1 | Dev Memorial Public School, Garhmukteshwar | 0.28 | 83 | 6.86 | 10 | 0.000 | 0.00 | 0.30 | 60 | 40 | 167 | Safe |

Lab Assistant

Rajni

Chemist

S. T. Kankare